

RE: Request for Average Runtime Information (Portable Turbines)

From Shannon Lynn <slynn@trinityconsultants.com>

Date Fri 7/10/2026 2:03 PM

To Jaricus Whitlock <jwhitlock@mdeq.ms.gov>

Cc Slater Smith <Slater.Smith@trinityconsultants.com>; Kathryn Jordan <Kathryn.Jordan@trinityconsultants.com>

This Message Is From an External Sender

This message came from outside your organization.

As requested. If you have any questions, please do not hesitate to reach out to me.

Unit	Unit Type	Control	Total Power Output	Date Added	June Hours	June Daily Avg
1	SMT-130	SCR	13	8/1/2025	397	13.2
2	SMT-130	SCR	13	8/1/2025	386	12.9
3	SMT-130	SCR	13	8/1/2025	607	20.2
4	SMT-130	SCR	13	8/18/2025	641	21.4
5	SMT-130	SCR	13	8/19/2025	477	15.9
6	SMT-130	SCR	13	8/20/2025	656	21.9
7	SMT-130	SCR	13	8/21/2025	390	13.0
8	Gen 8 TM2500	Demin Water	35	8/19/2025	611	20.4
9	Gen 8 TM2500	Demin Water	35	8/23/2025	602	20.1
10	Gen 7 TM2500	Demin Water	25	8/28/2025	530	17.7
11	Gen 7 TM2500	Demin Water	25	8/28/2025	495	16.5
12	Gen 6 TM2500	Demin Water	22	8/26/2025	648	21.6
13	Gen 6 TM2500	Demin Water	22	8/26/2025	557	18.6
14	Gen 6 TM2500	Demin Water	22	8/27/2025	638	21.3
15	Gen 6 TM2500	Demin Water	22	8/28/2025	658	21.9
16	Gen 7 TM2500	Demin Water	25	8/28/2025	466	15.5
17	Gen 7 TM2500	Demin Water	25	8/29/2025	674	22.5
18	Gen 8 TM2500	Demin Water	25	8/25/2025	524	17.5
19	Gen 8 TM2500	Demin Water	25	12/18/2025	689	23.0
20	Gen 7 TM2500	Demin Water	25	12/18/2025	703	23.4
21	SMT-130	SCR	13	11/30/2025	483	16.1
22	SMT-130	SCR	13	11/30/2025	545	18.2
23	SMT-130	SCR	13	11/30/2025	646	21.5
24	SMT-130	SCR	13	12/3/2025	603	20.1
25	SMT-130	SCR	13	12/5/2025	602	20.1
26	SMT-130	SCR	13	12/7/2025	479	16.0
27	SMT-130	SCR	13	1/6/2026	227	7.6
28	Gen 8 TM2500	Demin Water	30	3/25/2026	555	18.5
29	Gen 8 TM2500	Demin Water	30	5/2/2026	550	18.3

30	Gen 8 TM2500	Demin Water	30	4/3/2026	720	24.0
31	Gen 8 TM2500	Demin Water	30	3/25/2026	37	1.2
32	Gen 8 TM2500	Demin Water	30	4/27/2026	549	18.3
33	Gen 8 TM2500	Demin Water	30	3/27/2026	485	16.2
34	Mitsubishi FT8	Demin Water	30	3/24/2026	153	5.1
35	Mitsubishi FT8	Demin Water	30	3/25/2026	251	8.4
36	Mitsubishi FT8	Demin Water	30	3/25/2026	202	6.7
37	Mitsubishi FT8	Demin Water	30	3/25/2026	213	7.1
38	Mitsubishi FT8	Demin Water	30	4/3/2026	10	0.3
39	Mitsubishi FT8	Demin Water	30	4/3/2026	188	6.3
40	Mitsubishi FT8	Demin Water	30	4/23/2026	83	2.8
41	Mitsubishi FT8	Demin Water	30	4/28/2026	30	1.0
42	Gen 4 TM2500	Demin Water	25	4/28/2026	119	4.0
43	Gen 4 TM2500	Demin Water	25	4/28/2026	91	3.0
44	Gen 4 TM2500	Demin Water	25	4/28/2026	240	8.0
45	Gen 4 TM2500	Demin Water	20	5/1/2026	235	7.8
46	Gen 4 TM2500	Demin Water	20	6/10/2026	182	6.1
47	Gen 4 TM2500	Demin Water	20	5/1/2026	0	0.0
48	Gen 8 TM2500	Demin Water	30	5/6/2026	325	10.8
49	Gen 8 TM2500	Demin Water	30	5/2/2026	348	11.6
50	Gen 8 TM2500	Demin Water	30	5/2/2026	0	0.0
51	Gen 8 TM2500	Demin Water	30	5/2/2026	2	0.1
52	Gen 8 TM2500	Demin Water	30	5/2/2026	228	7.6
53	Gen 8 TM2500	Demin Water	30	5/2/2026	0	0.0
54	Gen 6 TM2500	Demin Water	25	5/3/2026	370	12.3
55	Gen 6 TM2500	Demin Water	25	6/9/2026	339	11.3
56	Mitsubishi FT8	Demin Water	30	5/7/2026	0	0.0
57	Mitsubishi FT8	Demin Water	30	5/6/2026	0	0.0
58	Mitsubishi FT8	Demin Water	30	5/9/2026	0	0.0
59	Mitsubishi FT8	Demin Water	30	5/9/2026	0	0.0
60	Gen 6 TM2500	Demin Water	25	~6/19/2026	0	0.0

Shannon G. Lynn, P.E., C.M.
Principal Consultant

1701 Centerview Drive Suite 109 Little Rock, AR 72211
Email: slynn@trinityconsultants.com

From: Jaricus Whitlock <jwhitlock@mdeq.ms.gov>
Sent: Thursday, July 9, 2026 10:59 AM
To: Shannon Lynn <slynn@trinityconsultants.com>
Cc: Slater Smith <Slater.Smith@trinityconsultants.com>; Kathryn Jordan <Kathryn.Jordan@trinityconsultants.com>
Subject: Re: Request for Average Runtime Information (Portable Turbines)

Good Morning Shannon,

Thank you for the update on this request. If possible (at this time), I also request an update on my request for a meeting with you all and the facility.

Best Regards,

Jaricus Whitlock, P.E.
Chief, Air Division
Office of Pollution Control
Mississippi Dept. of Environmental Quality
P.O. Box 2261
Jackson, MS 39225

Office: (601) 961-5303

From: Shannon Lynn <slynn@trinityconsultants.com>
Sent: Thursday, July 9, 2026 8:55 AM
To: Jaricus Whitlock <jwhitlock@mdeq.ms.gov>
Cc: Slater Smith <Slater.Smith@trinityconsultants.com>; Kathryn Jordan <Kathryn.Jordan@trinityconsultants.com>
Subject: RE: Request for Average Runtime Information (Portable Turbines)

I have been provided the data requested below for Units 1-27 and have been doggedly pursuing the same information for the balance of the turbines.

Shannon G. Lynn, P.E., C.M.
Principal Consultant

P 501.225.6400 x5404 M [REDACTED]
1701 Centerview Drive Suite 109 Little Rock, AR 72211
Email: slynn@trinityconsultants.com

From: Jaricus Whitlock <jwhitlock@mdeq.ms.gov>
Sent: Wednesday, June 17, 2026 12:47 PM
To: Shannon Lynn <slynn@trinityconsultants.com>; Slater Smith <slater.smith@trinityconsultants.com>; Kathryn Jordan <kathryn.jordan@trinityconsultants.com>
Subject: Request for Average Runtime Information (Portable Turbines)

Good Morning All!

In light of the number of portable turbines currently on-site, I kindly request information that reflects the typical average daily operational time for all units (i.e., 1 through 60). As this requested information is to update that which was originally shared November 5, 2025 (please see attached), please feel free to denote if the values originally shared for Unit No. 1 through 18 are still valid.

Please feel free to contact me if you have any questions.

Best Regards,

Jaricus Whitlock, P.E.
Chief, Air Division
Office of Pollution Control
Mississippi Dept. of Environmental Quality
P.O. Box 2261
Jackson, MS 39225

Office: (601) 961-5303

