
RE: Updated count

From Shannon Lynn <slynn@trinityconsultants.com>
Date Thu 12/11/2025 11:32 AM
To Jaricus Whitlock <jwhitlock@mdeq.ms.gov>

This Message Is From an External Sender

This message came from outside your organization.

- Please confirm that nine (9) additional portable turbines - Units 19 through 27 - have been brought on-site. **I have been told that they will be onsite by December 18.**
- Will any of the nine (9) additional portable turbines to be included within the "permanent turbine cluster" associated with the proposed PSD permitting action? **No, none of these will be.**
- Is the phrase "*no unit running or will run prior to SCR on 130's and water injection on 2500's*" specific to the nine (9) additional portable turbines? (i.e., are Units 1 through 18 still operationally?) **This is correct. Units 1 through 18 are operational with pollution control equipment. 19-27 will not operate until outfitted with control equipment.**

Shannon G. Lynn, P.E., C.M.
Principal Consultant

P 501.225.6400 x5404 M [REDACTED]
1701 Centerview Drive Suite 109 Little Rock, AR 72211
Email: slynn@trinityconsultants.com

From: Jaricus Whitlock <jwhitlock@mdeq.ms.gov>
Sent: Wednesday, December 10, 2025 6:01 PM
To: Shannon Lynn <slynn@trinityconsultants.com>
Subject: Re: Updated count

Good Evening Shannon,

Thank you for the update. To ensure that my forthcoming internal update is correct, I ask that you please provide the following clarification:

- Please confirm that nine (9) additional portable turbines - Units 19 through 27 - have been brought on-site.
- Will any of the nine (9) additional portable turbines to be included within the "permanent turbine cluster" associated with the proposed PSD permitting action?
- Is the phrase "*no unit running or will run prior to SCR on 130's and water injection on 2500's*" specific to the nine (9) additional portable turbines? (i.e., are Units 1 through 18 still operationally?)

Thank You!

Jaricus Whitlock, P.E.
Chief, Air Division
Office of Pollution Control
Mississippi Dept. of Environmental Quality
P.O. Box 2261
Jackson, MS 39225

Office: (601) 961-5303

From: Shannon Lynn <slynn@trinityconsultants.com>
Sent: Wednesday, December 10, 2025 11:38 AM
To: Jaricus Whitlock <jwhitlock@mdeq.ms.gov>
Subject: Updated count

Revised inventory, no unit running or will run prior to SCR on 130's and water injection on 2500's

<u>Unit Number</u>	<u>Unit Type</u>	<u>Total Power Output</u>
Unit 1	SMT130	13
Unit 2	SMT130	13
Unit 3	SMT130	13
Unit 4	SMT130	13
Unit 5	SMT130	13
Unit 6	SMT130	13
Unit 7	SMT130	13
Unit 8	Gen 8 TM2500	25
Unit 9	M35	25
Unit 10	Gen 7 TM2500	25
Unit 11	Gen 7 TM2500	25
Unit 12	Gen 6 TM2500	22
Unit 13	Gen 6 TM2500	22
Unit 14	Gen 6 TM2500	22
Unit 15	Gen 6 TM2500	22
Unit 16	Gen 7 TM2500	25
Unit 17	Gen 7 TM2500	25
Unit 18	Gen 8 TM2500	25
Unit 19	Gen 8 TM2500	25
Unit 20	Gen 7 TM2500	25
Unit 21	SMT130	13
Unit 22	SMT130	13
Unit 23	SMT130	13
Unit 24	SMT130	13
Unit 25	SMT130	13
Unit 26	SMT130	13
Unit 27	SMT130	13

Principal Consultant

P 501.225.6400 x5404 M 

1701 Centerview Drive Suite 109 Little Rock, AR 72211

Email: slynn@trinityconsultants.com

Connect with us: [LinkedIn \[linkedin.com\]](#) / [YouTube \[youtube.com\]](#) / [breeze-software.com \[breeze-software.com\]](#)

Stay current on EHS issues. [Subscribe \[trinityconsultants.com\]](#) today to receive Trinity's free [EHS Quarterly \[trinityconsultants.com\]](#).

View our capabilities in the [Environmental Consulting \[trinityconsultants.com\]](#), [Built Environment \[trinityconsultants.com\]](#), [Life Sciences \[trinityconsultants.com\]](#), and [Water & Ecology \[trinityconsultants.com\]](#) markets.

Connect with us: [LinkedIn \[linkedin.com\]](#) / [Facebook \[facebook.com\]](#) / [Twitter \[twitter.com\]](#) / [YouTube \[youtube.com\]](#) / [trinityconsultants.com \[trinityconsultants.com\]](#)

Stay current on environmental issues. [Subscribe \[trinityconsultants.com\]](#) today to receive Trinity's free *EHS Quarterly*.