

BEFORE THE MISSISSIPPI COMMISSION
ON ENVIRONMENTAL QUALITY

MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

VS.

ORDER NO. 7739 26

MZX TECH LLC
2875 STANTON ROAD
SOUTHAVEN, MS 38671

AMENDMENT TO AGREED ORDER

COME NOW the Mississippi Commission on Environmental Quality ("Commission"), acting through the staff and Executive Director of the Mississippi Department of Environmental Quality (MDEQ), and MZX Tech LLC (MZX), in the above-captioned cause, and agree to amend the Agreed Order entered July 30, 2026, in Agreed Order No. 7739 26 ("Agreed Order"), as follows:

1. Incorporation and Definitions. The Agreed Order is incorporated into this Amendment by reference. Capitalized terms not otherwise defined in this Amendment have the meanings assigned to them in the Agreed Order.

2. Amendment to Article 1. Article 1 of the Agreed Order is amended by adding the following paragraphs at the end of Article 1, without deleting or replacing any existing text:

Following entry of this Agreed Order, MZX requested a limited revision to the Retirement Dates in Appendix A for operational efficiency. Under the proposed turbine swap, MZX will cease operation of Mitsubishi FT8 Turbines Nos. 57 and 58 no later than August 27, 2026, in exchange for allowing Gen 6 TM2500 Turbine No. 15 and Gen 7 TM2500 Turbine No. 16 to continue operation through revised Retirement Dates of May 5, 2027, and May 8, 2027, respectively. MZX represents that the applicable emission rates for TM2500 Turbines Nos. 15 and 16 are the same as the applicable emission rates for Mitsubishi FT8 Turbines Nos. 57 and 58, and that this swap will not result in any net increase in emissions. Based on these representations and subject to the conditions in Article 2, MDEQ is exercising its discretion to allow Turbines Nos. 15 and 16 to continue to operate as mobile sources through their revised Retirement Dates.

MZX also identified other inventory information in Appendix A requiring correction or clarification. The Amended Appendix A corrects certain turbine manufacturer and model designations, reports the applicable OEM nameplate ratings at ISO conditions in place of the previously reported nameplate capacity and expected local power output figures, identifies turbines that have already been retired, and reflects that Turbine No. 53 was never delivered to the Stanton Road Facility.

3. Amendment to Article 2. Article 2 of the Agreed Order is amended by adding the following new Paragraph H after Paragraph G, without deleting or replacing any existing text:

H. Notwithstanding Paragraphs A through C above or the Retirement Dates shown in Appendix A as originally executed, the Retirement Dates for Turbines Nos. 15, 16, 57, and 58 are revised as follows:

- (a) Turbine No. 15: May 5, 2027;
- (b) Turbine No. 16: May 8, 2027;
- (c) Turbine No. 57: August 27, 2026; and
- (d) Turbine No. 58: August 27, 2026.

MZX shall cease operation of Turbines Nos. 57 and 58 at the Stanton Road Facility no later than August 27, 2026. MZX may operate Turbine No. 15 after August 27, 2026, only if Turbine No. 57 has ceased operation, and may operate Turbine No. 16 after August 27, 2026, only if Turbine No. 58 has ceased operation. Neither Turbine No. 57 nor Turbine No. 58 will return to operation after ceasing operations per this Amendment, and both will be moved off-site as soon as practicable after ceasing operation. All other requirements and conditions of the Agreed Order, including the operation of the emission controls designated in Appendix A and all applicable reporting obligations, remain applicable to these turbines. The revised schedule is authorized solely for operational efficiency and shall not authorize any net increase in emissions or any increase in the number of mobile turbines operating at the Stanton Road Facility.


4. Amendment and Restatement of Appendix A. Appendix A to the Agreed Order is amended and restated in its entirety as set forth in Attachment A to this Amendment, titled Amended Appendix A, which is incorporated into the Agreed Order. Each reference in the Agreed Order to Appendix A shall mean the Amended Appendix A.

5. Continuing Effect. Except as expressly amended by this Amendment, the Agreed Order remains unchanged and in full force and effect. If any provision of this Amendment conflicts with the Agreed Order, this Amendment controls.

6. Effective Date. This Amendment becomes effective when it has been agreed to by MZX and ordered by the Commission.

ORDERED, this the 11th day of September, 2026.


MISSISSIPPI COMMISSION ON
ENVIRONMENTAL QUALITY

BY: 

CHRIS WELLS
EXECUTIVE DIRECTOR
MISSISSIPPI DEPARTMENT OF
ENVIRONMENTAL QUALITY

AGREED, this the 10th day of September, 2026.

MZX TECH LLC

BY: 

NAME: James Burnham

TITLE: General Counsel

STATE OF _____

COUNTY OF _____

PERSONALLY appeared before me, the undersigned authority in and for the jurisdiction aforesaid, the within named _____, who first being duly sworn did state upon his or her oath and acknowledge to me that he or she is the _____ of MZX Tech LLC and is authorized to sign and enter this Amendment on its behalf.

SWORN AND SUBSCRIBED BEFORE ME, this the _____ day of _____, 2026.

*See a Hatched
P.P.*

NOTARY PUBLIC

My Commission expires: _____

CALIFORNIA JURAT

GOVERNMENT CODE § 8202


A notary public or other officer completing this certificate verifies only the identity of the individual who signed the document to which this certificate is attached, and not the truthfulness, accuracy, or validity of that document.

State of California

County of Santa Clara

Subscribed and sworn to (or affirmed) before me on

this 10 day of Sept, 2026, by
Date Month Year



(1) James Burnham

(and (2) _____),
Name(s) of Signer(s)

proved to me on the basis of satisfactory evidence to be the person(s) who appeared before me.

Signature ML ML
Signature of Notary Public

Place Notary Seal and/or Stamp Above

OPTIONAL

Completing this information can deter alteration of the document or fraudulent reattachment of this form to an unintended document.

Description of Attached Document

Title or Type of Document: _____

Document Date: _____ Number of Pages: _____

Signer(s) Other Than Named Above: _____

ATTACHMENT A
AMENDED APPENDIX A

Unit	Unit Type	Control	OEM Nameplate (ISO) (MW)¹	Date Added	Retirement Date
1	SMT-130	SCR+oxcat	16	8/1/2025	12/31/2026
2	SMT-130	SCR+oxcat	16	8/1/2025	12/31/2026
3	SMT-130	SCR+oxcat	16	8/1/2025	12/31/2026
4	SMT-130	SCR+oxcat	16	8/18/2025	12/31/2026
5	SMT-130	SCR+oxcat	16	8/19/2025	12/31/2026
6	SMT-130	SCR+oxcat	16	8/20/2025	12/31/2026
7	SMT-130	SCR+oxcat	16	8/21/2025	12/31/2026
8	TM2500 (Gen 8) (Retired)	Demin Water	35	8/19/2025	8/18/2026
9	M35 (Retired)	Demin Water	35	8/23/2025	8/22/2026
10	TM2500 (Gen 7) (Retired)	Demin Water	30.988	8/28/2025	8/27/2026
11	TM2500 (Gen 7) (Retired)	Demin Water	30.988	8/28/2025	8/27/2026
12	TM2500 (Gen 6) (Retired)	Demin Water	30.988	8/26/2025	8/25/2026
13	TM2500 (Gen 6) (Retired)	Demin Water	30.988	8/26/2025	8/25/2026
14	TM2500 (Gen 6) (Retired)	Demin Water	30.988	8/27/2025	8/26/2026
15	TM2500 (Gen 6)	Demin Water	30.988	8/28/2025	5/5/2027
16	TM2500 (Gen 7)	Demin Water	30.988	8/28/2025	5/8/2027
17	TM2500 (Gen 7) (Retired)	Demin Water	30.988	8/29/2025	8/28/2026

¹ OEM nameplate at ISO conditions does not include auxiliary loads, local ambient condition adjustments, or unit-specific derates. OEM nameplate at ISO conditions does include generator constraints (e.g., where the size of the installed generator constrains the maximum capacity of the engine).

Unit	Unit Type	Control	OEM Nameplate (ISO) (MW) ¹	Date Added	Retirement Date
18	TM2500 (Gen 8) (Retired)	Demin Water	35	8/25/2025	8/24/2026
19	TM2500 (Gen 8)	Demin Water	35	12/18/2025	12/17/2026
20	TM2500 (Gen 6)	Demin Water	30.988	12/18/2025	12/17/2026
21	SMT-130	SCR+oxcat	16	11/30/2025	12/31/2026
22	SMT-130	SCR+oxcat	16	11/30/2025	12/31/2026
23	SMT-130	SCR+oxcat	16	11/30/2025	12/31/2026
24	SMT-130	SCR+oxcat	16	12/3/2025	12/31/2026
25	SMT-130	SCR+oxcat	16	12/5/2025	12/31/2026
26	SMT-130	SCR+oxcat	16	12/7/2025	12/31/2026
27	SMT-130	SCR+oxcat	16	1/6/2026	12/31/2026
28	TM2500 (Gen 8)	Demin Water	36.9	3/25/2026	3/24/2027
29	TM2500 (Gen 6)	Demin Water	30.988	5/2/2026	5/1/2027
30	TM2500 (Gen 8)	Demin Water	36.9	4/3/2026	4/2/2027
31	JT35/35060	Demin Water	35	3/25/2026	3/24/2027
32	JT35/35060	Demin Water	35	4/27/2026	4/26/2027
33	JT35/35060	Demin Water	35	3/27/2026	3/26/2027
34	FT8 MOBILEPAC	Demin Water	29.4	3/24/2026	3/23/2027
35	FT8 MOBILEPAC	Demin Water	29.4	3/25/2026	3/24/2027
36	FT8 MOBILEPAC	Demin Water	29.4	3/25/2026	3/24/2027
37	TM2500 (Gen 8)	Demin Water	35	3/25/2026	3/24/2027
38	FT8 MOBILEPAC	Demin Water	29.4	4/3/2026	4/2/2027
39	FT8 MOBILEPAC	Demin Water	29.4	4/3/2026	4/2/2027
40	FT8 MOBILEPAC	Demin Water	29.4	4/23/2026	4/22/2027
41	FT8 MOBILEPAC	Demin Water	29.4	4/28/2026	4/27/2027
42	FT8 MOBILEPAC	Demin Water	29.4	4/28/2026	4/27/2027

Unit	Unit Type	Control	OEM Nameplate (ISO) (MW) ¹	Date Added	Retirement Date
43	TM2500 (Gen 4)	Demin Water	22.5	4/28/2026	4/27/2027
44	TM2500 (Gen 2)	Demin Water	22.5	4/28/2026	4/27/2027
45	TM2500 (Gen 4)	Demin Water	22.5	5/1/2026	4/30/2027
46	TM2500 (Gen 2)	Demin Water	22.5	6/10/2026	6/9/2027
47	TM2500 (Gen 2)	Demin Water	22.5	5/1/2026	4/30/2027
48	TM2500 (Gen 2)	Demin Water	22.5	5/6/2026	5/5/2027
49	TM2500 (Gen 8)	Demin Water	35	5/2/2026	5/1/2027
50	TM2500 (Gen 8)	Demin Water	36.9	5/2/2026	5/1/2027
51	TM2500 (Gen 8)	Demin Water	35	5/2/2026	5/1/2027
52	TM2500 (Gen 8)	Demin Water	35	5/2/2026	5/1/2027
53	Turbine Never Delivered	N/A	N/A	N/A	N/A
54	TM2500 (Gen 8)	Demin Water	35	5/3/2026	5/2/2027
55	TM2500 (Gen 6)	Demin Water	30.988	6/9/2026	6/8/2027
56	TM2500 (Gen 7)	Demin Water	30.988	5/7/2026	5/6/2027
57	FT8 MOBILEPAC (Retired)	Demin Water	29.4	5/6/2026	8/27/2026
58	FT8 MOBILEPAC (Retired)	Demin Water	29.4	5/9/2026	8/27/2026
59	FT8 MOBILEPAC	Demin Water	29.4	5/9/2026	5/8/2027
60	FT8 MOBILEPAC	Demin Water	29.4	5/9/2026	5/8/2027
61	FT8 MOBILEPAC	Demin Water	29.4	7/9/2026	7/8/2027
62	FT8 MOBILEPAC	Demin Water	29.4	7/9/2026	7/8/2027
63	FT8 MOBILEPAC	Demin Water	29.4	7/9/2026	7/8/2027
64	FT8 MOBILEPAC	Demin Water	29.4	7/10/2026	7/9/2027
65	FT8 MOBILEPAC	Demin Water	29.4	7/10/2026	7/9/2027
66	FT8 MOBILEPAC	Demin Water	29.4	7/10/2026	7/9/2027

Unit	Unit Type	Control	OEM Nameplate (ISO) (MW)¹	Date Added	Retirement Date
67	FT8 MOBILEPAC	Demin Water	29.4	7/14/2026	7/13/2027
68	FT8 MOBILEPAC	Demin Water	29.4	7/15/2026	7/14/2027
69	FT8 MOBILEPAC	Demin Water	29.4	7/15/2026	7/14/2027